





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



APPROVAL CERTIFICATE		Certificate N° 10/DE/2279-2-REV 0
Manufacturer	Name	Rudolf von Scheven GmbH
	Address	Wuppertaler Str. 10-12, 45549 Sprockhovel Germany
<u>Concerned Equipment</u> : Gas bundle valves for Acetylene – Models K020806000-I, K021206000-I, K020806600-I, K021206600-I, K020806670-I, K021206670-I and K021203670-I.		
		
<p>This certificate covers the homologation of the above mentioned valves (see pictures above) intended to equip acetylene gas bundles qualified for a risk category 3 according the European directive 99/36/EC.</p> <p>This equipment is defined by:</p> <ul style="list-style-type: none"> - Manufacturer name - A maximum working pressure of 25 bar, - A temperature working range from -20°C to +65°C - Model and production name <p>The results of the homologation tests are recorded in our reports L. 41.930 dd. 26/10/2010 and L. 43.541 dd. 01/07/2011.</p>		
<p><u>MARKING:</u> The approved valves will be marked in a permanent way with, at least, the following inscriptions:</p> <ul style="list-style-type: none"> - Manufacturers identification - Maximum working pressure of 25 bar - DN sizes (6 or 10 mm) - The model reference 		
<p>The manufacturer is only authorized to affix above-mentioned marking on regulators of the approved type. Any modification to the type of above mentioned approved regulator is subject to re-examination.</p> <p style="text-align: center;">Approval is valid until 10/2020</p>		
Date: 04/07/2011	Name: Ch. Leplat	Position General Manager
Notify Body Stamp :	APRAGAZ Belgium Inspecting Authority	Signature 
Notify Body reference:	L1010/5442/THT- L1106/5668/THT 1010/P12841/TPED01	