



Rudolf von Scheven GmbH, Sprockhövel

Office: Dortmund

Date: 22 September 2015

This Certificate is issued to the above client to certify that a surveyor to Lloyd's Register did, at their request, attend the undermentioned manufacturer for the purpose of inspecting and witnessing tests on the product listed below.

**FLAME – RESISTANCE TEST CERTIFICATE
OF
Fire Safe Ball Valve – DN 50 (2") and below / until DN 100 (4")**

Test requirements:	DIN EN ISO 10497:2010-06 API 607, 6 th edition
Tested sizes of ball valve:	DN 50, PN 40
Drawing no.:	00900-2 (fixed flange) 00900-3 (lose flanges)
Qualified Sizes:	DN 50 (2") and below, DN 65 (2 1/2"), DN 80 (3") and DN 100 (4")
Qualified Pressure Ratings:	Class 300, Class 400, Class 600, PN 40, PN 63 and PN 100
Test procedure and results:	as per test report IBB-1348, dated 27.01.2015

The following examinations were carried out with satisfactory results in accordance with the above specification:

- Reviewed test specification and accepted test facilities
- Verified selected ball valves against drawing and visual inspection to compliance to above stated type
- Checked calibration status of used test gauges
- Witnessed of flame-resistance test
- Reviewed and endorsed documentation

For further details please refer to attached documentation.

EN/SCH



For G. Milke: S. Schumacher
Surveyor to Lloyd's Register EMEA

A subsidiary of Lloyd's Register Group Limited

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

TEST Report

Flame - resistance tests according to DIN EN ISO 10497 Report IBB – 1348 / LRDTM 1520139/1

This report confirms the testing of a representative valve in compliance with the DIN EN ISO 10497, 2010, and with API 607, 6th edition.

Manufacturer	Rudolf von Scheven GmbH Wuppertaler Str. 10-12 45549 Sprockhövel	
Test Valve	Ball Valve DN 50 PN 40 Flange end connections, Lever operated Nominal bore: DN 50 Pressure rating: PN 40 Body/Bonnet material: 1.0619/1.0570 Ball material: 1.0715 Ball seal material: PTFE Drawing number: 00900-2 Operation device: Lever	
Date of Testing	27 January 2015	
Test Report	5 pages	
Qualified sizes	DN 50 and below, DN 65, DN 80, DN 100 2" and below, 2 1/2", 3", 4"	
Qualified pressure ratings	Class 300, Class 400, Class 600 PN 40, PN 63, PN 100	
Testing location	Laboratory of Dr.-Ing. T. Bäumer GmbH, Altensenner Weg 75, D - 32052 Herford	
Test requirements	The tests were carried out strictly in accordance with DIN EN ISO 10497, 2010, and with API 607, 6th edition	
Participants	Mr. G. Milke Mr. R. Hatko Mr. Dr. T. Bäumer	Lloyds Register, EMEA Rudolph von Scheven GmbH Dr.-Ing. T. Bäumer GmbH

Test examination

The water filled valve was subjected to fire for 30 minutes at a temperature between 750 °C and 1000 °C and a pressure of e.g. 2,0 barg. After the burn period the through-seat-leakage was determined and after a cool down period the external leakage and the through-seat-leakage were measured. Then the valve was opened, and the external leakage was determined.

Instrumentation

Temperature: 6 Thermocouples, Ni Cr Ni, accuracy 1 K.

Pressure: Pressure transmitter, accuracy 0,5 %.

PC-system: AD converter board, software for measuring, Personal Computer

The measuring devices are controlled by an accredited calibration service.

Body cavity set relief pressure and setting: 60 barg

Test results

Time of test start (ignition of burners): 10.05 am

Temperatures and pressure during burn period

Time [s]	p [barü]	T _{Fire1} [°C]	T _{Fire2} [°C]	T _{Cal1} [°C]	T _{Cal2} [°C]	T _{Bonnet} [°C]	T _{Body} [°C]
.0	2.1	17.2	7.1	11.6	9.5	6.6	12.8
30.0	2.0	771.5	652.6	66.2	55.6	196.7	199.8
60.0	2.1	761.2	683.1	126.1	104.8	203.2	191.4
90.0	2.1	797.3	779.7	207.5	162.0	296.1	249.5
120.0	2.1	806.2	796.4	282.7	234.6	321.6	315.0
150.0	2.1	841.3	786.7	354.8	307.0	344.4	346.6
180.0	2.1	898.7	822.6	422.2	376.4	404.3	348.0
210.0	2.1	916.7	873.2	484.9	441.5	470.8	333.0
240.0	2.1	922.4	887.1	539.5	499.3	498.3	365.8
270.0	2.1	895.3	888.4	588.4	547.0	486.1	399.2
300.0	2.1	859.4	867.0	628.9	587.3	489.8	420.4
330.0	2.1	841.9	851.0	660.2	618.4	502.7	425.7
360.0	2.1	892.2	871.0	688.0	646.9	540.2	429.3
390.0	2.1	958.1	952.8	714.8	672.7	591.8	449.5
420.0	2.1	916.7	945.1	738.4	699.3	573.6	476.8
450.0	2.1	932.3	942.0	756.3	721.3	606.3	474.8
480.0	2.1	925.9	975.1	772.1	740.5	624.5	496.7
510.0	2.1	916.6	917.8	786.8	760.0	623.1	502.9

540.0	2.1	881.4	930.4	800.5	775.7	610.0	529.5
570.0	2.1	929.2	975.1	815.0	779.6	648.0	525.6
600.0	2.1	890.7	945.5	830.4	800.6	630.8	557.5
630.0	2.1	864.4	901.8	845.3	820.6	626.3	555.8
660.0	2.1	874.6	954.4	853.4	824.9	638.3	562.2
690.0	2.1	914.2	987.9	862.7	830.3	699.6	570.6
720.0	2.1	888.8	968.3	874.2	842.7	696.3	573.1
750.0	2.1	892.7	921.4	881.8	849.5	742.8	582.2
780.0	2.1	866.0	937.7	891.8	862.8	689.2	618.1
810.0	2.1	917.4	989.5	895.1	862.7	733.9	605.6
840.0	2.1	890.4	962.0	901.7	876.8	733.8	627.5
870.0	2.1	865.8	902.8	908.4	889.8	710.3	611.3
900.0	2.1	855.3	835.8	913.3	896.8	699.3	597.6
930.0	2.1	857.1	906.7	911.2	886.3	704.7	621.3
960.0	2.1	863.0	911.8	910.9	876.3	750.5	619.3
990.0	2.1	854.1	943.3	914.3	879.1	751.4	653.7
1020.0	2.1	874.2	941.4	916.6	881.3	789.8	654.7
1050.0	2.1	844.4	874.8	918.6	893.2	748.7	640.9
1080.0	2.1	882.0	946.2	914.1	876.8	766.7	658.7
1110.0	2.1	859.6	927.8	917.8	882.6	780.1	646.5
1140.0	2.1	879.8	942.9	918.0	877.3	791.7	656.3
1170.0	2.1	858.2	883.1	916.9	878.3	742.0	633.3
1200.0	2.1	864.8	977.0	910.3	861.5	778.7	655.5
1230.0	2.1	835.2	922.6	909.9	860.5	740.3	636.7
1260.0	2.1	840.1	855.7	907.2	863.6	708.0	613.7
1290.0	2.1	820.4	916.5	900.1	847.9	693.8	638.1
1320.0	2.1	832.8	989.5	897.0	842.0	710.2	648.4
1350.0	2.1	841.7	999.1	895.0	845.7	689.5	664.2
1380.0	2.1	809.8	882.5	894.6	854.2	662.1	620.2
1410.0	2.0	830.1	907.9	886.2	842.9	675.1	624.4
1440.0	2.0	874.2	915.7	882.1	835.6	664.1	617.5
1470.0	2.1	861.7	891.8	879.2	828.8	654.7	607.6
1500.0	2.1	841.3	977.5	876.0	821.3	664.4	637.2
1530.0	2.1	790.0	804.3	873.3	823.5	617.7	562.1
1560.0	2.1	845.2	939.8	867.9	808.5	642.9	606.4
1590.0	2.1	854.3	900.7	868.7	813.0	629.7	587.4
1620.0	2.1	787.4	918.8	868.1	808.2	616.1	587.0
1650.0	2.0	861.7	937.8	865.4	800.6	639.4	604.4
1680.0	2.0	861.7	913.3	864.5	797.9	633.2	589.7
1710.0	2.0	867.8	947.1	863.5	794.5	642.5	594.8
1740.0	2.1	815.3	853.0	862.1	793.6	601.1	557.1
1770.0	2.1	853.0	896.5	858.6	784.0	625.7	571.7
1800.0	2.1	824.6	829.4	858.8	789.7	622.3	555.4

Time required for valve to cool down to 100 °C:	6 min
Test valve unseated:	Yes
Test valve moved to the fully open position:	Yes

	Leakage [ml/DN/min]	Allowable leakage [ml/DN/min]
Through-seat-leakage in burning phase:	0,1	4,0
External leakage in burning and cooling phase:	0,0	1,0
Through-seat-leakage at low pressure:	0,0	1,6
External leakage after unseating the valve:	0,5	1,0


Comments on the results

The test valve is a Ball Valve with a bore in the ball inlet. Because it is intended for one-directional installation, the tests were carried out only for one flow direction.

Conclusion

The test valve fulfilled the test requirements according to DIN EN ISO 10497, 2010, and API 607, 6th edition. Only allowable through-seat-leakages and external leakages were observed during the tests.

Herford, 27 January 2015




Mr. G. Milke
Surveyor





Rudolph von Scheven
GmbH

Mr. R. Hatko
Technical Department


Dr.-Ing. T. Bäumer
GmbH

Mr. Dr. T. Bäumer
Consultant engineer





POS-NR.	BENENNUNG	BESCHREIBUNG	MENGE
10	Gehäuse	1.0460	1
20	Einschraubstück	1.0570	2
25	Flanschblatt	1.0570	2
30	Kugel	1.0715	1
40	Dichtung	PTFE	2
50	Anschlagscheibe	1.0038	1
60	Spindel	1.0715	1
80	O-Ring	Viton	4
130	Lagering	PTFE	1
200	Unterlegscheibe	1.0038	1
201	Spannscheibe oder Wellenring	Stahl	1
202	Mutter niedrige Ausführung M20x1.5	DIN 936/439	1
210	Packung (Graphit)	Graphit	1
220	Graphitring 82x88	Graphit	2



Maßstab: 1:1.7		DIN ISO 13715 +0.3 -0.5		Allgemeintoleranzen nach DIN 2786-T1-m bis 6 ± 0.1, über 6-30 ± 0.2, über 30-120 ± 0.3, über 120-400 ± 0.5, über 400-1000 ± 0.8	
Werkstoff:		Benennung:		Fire-Safe-Hahn DN50 Class 300	
Gewicht: g		Name		Datum	
Gez. Hatko		12.01.2015			
Nr.	Änderung	Datum / Name	Gepr.		
Rudolf von Scheven GmbH Armaturenfabrik und Apparatebau 45538 Sprockhövel Postfach 1365 Tel.: 02324 9742-0 Fax: 02324 9742-10 www.von-scheven.de info@von-scheven.de					
Ersatz für:		Zeichnungs-Nr.		Änderung	
A3		Entwurf00900-3			